


## Connection box KR18KRL



Protection against outside attack. The tactile switch is used to show the cover has been disturbed.

Connect the TAMPER circuit to the TMP terminals. Once the lid is removed the circuit will be broken.

Ensure all cables are secure and cannot short out to other connections or components.

Note: The jumper in the central section of the PCB can be used to link the terminals from one side of the PCB to the other by fitting the headers to the selected pins.

*Nerival Oy*